

dist	at 5 m intervals	Filename	LEQ [dB]	31.5 Hz	63.0 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	
	generator number 1 only on	Houghton	one generator (of 3) running so only one set of coolers on										
1	gas plant vent	R1242	A	74.1	72.1	74.9	76.7	78.3	72.5	64.3	67	59.5	48
1	from building	R1243	B	73.1	72.9	79.6	79.8	74.8	71.2	66.4	63.7	55.5	45
1	from building	R1244	C	67.1	72.4	68.6	75.1	73.3	64.7	57.8	55.2	49.2	36.2
1	from building	R1245	D	61	70.5	68.3	70.9	63.2	58.6	54.3	50	45.6	33.6
1	from building	R1247	E	62.7	70.9	69	74.4	65.9	60	53.7	51.3	47.1	32
1	from building	R1248	F	71.2	74.7	73.6	79.4	77.9	68.5	58.9	59.9	54.2	41.7
1	from building	R1249	G	67.1	75.7	73.5	77	72.4	63.7	59.2	53.6	47.8	50.6
1	from building	R1250	H	63	73.6	70.5	72.9	61.7	61.6	57.2	50.7	41.4	39.9
1	from building	R1252	I	57.3	66.4	67.3	65.2	57.7	56.7	50.8	45.8	35	33.5
1	from building	R1253	J	59	68.8	68.5	68.7	57.1	58.6	52.7	44.5	35.1	31.2
1	from cooler	R1254	K	77.9	75.2	82.1	81.6	80.4	75.8	72.3	67.8	60.1	51.2
1	from cooler	R1255	L	77.6	73	79.9	79.4	82.4	74.8	71.1	65.6	59.7	50.5
1	from cooler	R1256	M	69.9	70.6	78	78.5	72.1	66.6	64.1	59.9	53.1	44.4
1	from cooler	R1257	N	65.3	67.6	76.5	73	68.9	62.1	59	54.5	46.5	36.7
1	from cooler	R1258	O	63.4	67.7	77.2	72	65.2	60.6	57	52.9	45.7	35.2
1	from building	R1259	P	61.5	66.2	69.3	70.5	65.3	59.7	53.4	48.1	40.9	32.1
1	from building	R1260	Q	56.1	64.6	61.4	70.5	55.6	48.7	47.7	42.9	33	26.2
1	from building - also traffic noise	R1262	R	55.8	62.8	65.7	68.7	54.7	49.1	50.1	44.9	33.4	24.4
1	from building - also traffic noise	R1265	S	50.5	64.3	61.5	58.8	52.2	48	44.5	39.5	33.7	28.3

